



# Circuit Summary Report

## Optical Wavelength Laboratories

Link ID: B1-F1-MC1-TC1  
Company Name: Acme Corp.  
Telephone Number: 800-555-1212

Page: 1  
Report Date: 6/10/2008

---

---

Circuit ID	1310nm			1550nm		
	P/F	O/H (dB)	Loss (dB)	P/F	O/H (dB)	Loss (dB)
R1-P1 Port 001	Pass	2.83	0.71	Pass	2.52	1.02
R1-P1 Port 002	Pass	2.26	1.28	Pass	2.35	1.19
R1-P1 Port 003	Pass	2.24	1.30	Pass	2.40	1.14
R1-P1 Port 004	Pass	2.81	0.73	Pass	2.62	0.92
R1-P1 Port 005	Pass	2.84	0.70	Pass	2.98	0.56
R1-P1 Port 006	Pass	2.56	0.98	Pass	3.10	0.44

---

---

Installer/Tester: \_\_\_\_\_  
Customer: \_\_\_\_\_

Date: \_\_\_\_\_  
Date: \_\_\_\_\_