



# Extech Micro Meters Models MO 500, MO 510, & MO 520

## Optical Power Meters

# User's Guide



## Table of Contents

### Unit 1 - Introduction

Why Use An Optical Fiber Power Meter?	1-1
Checking Your MicroMeter Firmware Version	1-1
Description	1-2
Applications	1-2
General Features	1-3
Keyboard Entry Method	1-3

### Unit 2 - Meter Functions

Operation	2-1
Power Units	2-1
Wavelengths	2-2
“Zeroing” or Setting an Optical Reference	2-2
Monitor Mode	2-2
Powering ON the Integrated LED Source (optional)	2-2
Main Menu	2-3
Stored Data Menu	2-3
Meter Setup	2-4
Manual Reference Method	2-4
Power Off	2-5

### Unit 3 - Fiber Certification

Overview	3-1
Operation	3-1
Power On	3-1
Fiber Certification	3-1
Definition of a link	3-1
Stored Data	3-4
Circuit Summary Printout	3-5

### Unit 4 - Appendices

Appendix A - Decibel Review	4-1
Appendix B - Dynamic Range Review	4-2
Appendix C - Glossary	4-3
Appendix D - MicroMeter Specifications	4-6
Appendix E - Warranty and Repair/Calibration Information	4-7
Appendix F - Cleaning and Care Instructions	4-8
Appendix G - Reference Cable Setup	4-9
Link Budget Calculation Worksheet	

### Why Use An Optical Fiber Power Meter?

Standards organizations such as the TIA or the ISO/IEC provide performance standards that the cabling plant must adhere to in order to support high-speed protocols such as Gigabit Ethernet. Fiber can be tested against these standards, ensuring that it is able to handle the high amount of traffic with a maximum amount of reliability.

These standards organizations also provide standards for administration of the cabling plant. These standards require a fiber link to be certified; that is, a report must be generated from appropriate test equipment for tracking and auditing purposes. These reports can also be used as verification of compliance to performance standards in case a question comes up about the quality of an installation. These signed documents cover the installer from liability provided that the link meets specified performance standards.

Our optical fiber power meters are designed with these standards in mind because we understand the importance of qualifying your fiber installations with standards-compliant test equipment. The meter you have just purchased also prints professionally formatted reports showing the conformity to these popular industry standards. You can print out these reports as a record of the original conformity to quality set by the standards. These documents signed by all associated parties may prove valuable in any future disputes concerning the installation.

### Checking Your MicroMeter Firmware Version

This manual is written for the MicroMeter firmware version 1.20e and later. It is not valid for previously released MicroMeter versions. Follow the instructions below to verify the meter's firmware version.

1 - Press **ON** to start up the meter.

2 - After the initial boot-up screen, your display should look like the diagram below. This screen only remains viewable for approximately 2 seconds.

If the firmware version is not V1.20e or later, contact Extech for the correct version of the manual.

**Company Name**

.....

**Company Phone**

.....

**Serial Number**

SN:MXnnnnnn

**Firmware Version**

V1.20e

### Description

The MicroMeter is a high accuracy, high resolution, microprocessor controlled, optical power meter. The meter has a wide dynamic range making it ideal for both single and multi-mode fiber testing.

It has an attractive handheld case, a backlit graphical liquid crystal display, and 18-key keypad for easy data entry. The meter comes with a small state-of-the-art UNIVERSAL adapter that is fully reliable for the use of ST, SC, FC or any 2.5 mm connectors which *saves money on consumables* (test cables wear out). It will operate for over 100 hrs on a single 9v battery and has built in auto shutdown.

The MicroMeter includes a built-in link wizard that helps the user easily calculate the allowable loss for the fiber runs that they will be measuring. The meter stores physical fiber information for up to four links. Link information includes: link name, date, fiber type, fiber length, connectors, splices, temperature, and calculated or entered reference power values for four wavelengths. In addition the meter will store up to 1000 measured data points with labels. Each value includes the fiber type and link.

The stored information can be selectively viewed, edited (measured again), printed, or deleted. The meter will print formatted reports of selected stored data directly using the built in serial port, or all of the stored data can be downloaded to a computer spreadsheet or our free Extech Reporter software to produce professional-looking formatted certification reports.

### Applications

*Attenuation and Loss Measurements.* After a fiber cable has been installed and terminated, it must be tested to determine if the fiber is installed correctly. A comparison of the actual power measurement and the reference value determines the loss of the fiber link.

*Fiber Network Certification.* The MicroMeter uses a loss wizard that is used for fiber certification against the popular industry cabling standard called the EIA/TIA 568-B. The user is prompted to enter several parameters, which allows the MicroMeter to calculate a certification reference value and store it in the meter. As the user stores data points in the meter using the loss wizard, the actual power level of the link is also stored. The data is then downloaded into our Extech Reporter software, where the actual power value is compared to the reference value. Certification reports can be printed out with details or summaries of the fibers being certified.


*Fiber Continuity Testing.* Continuity can be measured with the MicroMeter by placing a calibrated light source on one end of the fiber and the MicroMeter on the other end. This is also a simple way to measure the attenuation of the fiber.

*Patch Cord Testing.* Fiber links that are producing incorrect results may have bad patch cords. The MicroMeter can be used to test the attenuation of a patch cord to see if it is usable, or should be thrown out.

*Active Equipment Optical Power Measurements.* Active equipment needs to be measured periodically for correct power levels and stability. The transmitters in this equipment have a known power value. The MicroMeter can be directly attached to this equipment via a patch cord to check whether the transmitter is stable and is within the manufacturer's specified power range.

## General Features

- 1 2.5mm UNIVERSAL ADAPTER PORT - accepts standard 2.5mm ferrule connectors (ST, SC, FC).
- 2 COMPUTER PORT - port for downloading data from the meter to a PC via serial cable.
- 3 MULTIMODE LED SOURCE (optional) - the MicroMeter can come configured with an optional 850nm (MO510) or 1300nm (MO520) multimode LED source. Press the '4' key to activate the optional LED light source
- 4 LIQUID CRYSTAL DISPLAY (LCD) - displays power readings, menus, and information necessary for operation of the meter. The elements of the display are discussed in the appropriate units.
- 5 FUNCTION KEYS - activate the options on the Function Options Menu.
- 6 ALPHA NUMERIC KEYS - enter letters, numbers, and symbols into field prompts.
- 7 MENU KEY - used to enter the menu system.
- 8 DONE KEY - activates certain menu options.
- 9 BACK LIGHT KEY - toggles the LCD back light ON or OFF.
- 10 ON/OFF KEYS - turns the meter ON or OFF.



## Keyboard Entry Method

Several screens in the MicroMeter menu system require the user to enter some input, e.g. A fiber length measurement or a descriptive name for a fiber run. This feature allows the MicroMeter to be more user-friendly.

**Alpha-numeric Fields.** These fields allow the user to enter either a number, a letter, or a special character. This is accomplished by pressing and holding the key until the desired character appears. When the key is released, the cursor automatically advances to the next position.



**Numeric Fields.** These fields are for numeric input only, e.g. fiber length, user-defined reference values, etc. The cursor will automatically advance once a number key is pressed. Exception: some numeric operators may be required, such as the minus sign or a decimal point. The **DONE** key contains special characters. In this case, they are treated like alpha-numeric fields.

Press the **DONE** key when character input is complete.

# UNIT 2


## Meter Functions

### Operation

#### Power On

1 - Press the **ON** button.

2 - After a few seconds, a screen will appear that looks like the one below, called Immediate Mode.



#### Power Units

The MicroMeter is capable of displaying power readings in three different units. The user may toggle through these units by pressing **F1**:

**dBm (ABS).** This is an absolute (ABS) power measurement. It shows how much optical power is being received by the photodetector in decibels referenced to a milliwatt (dBm).

**dB (REL).** This is a relative (REL) power measurement. It shows the amount of optical power being received by the photodetector relative to a user-defined reference power (i.e. "zeroing" the meter). If a reference value has been set, toggling to REL mode will show the user how much optical power is being lost in the link.

**μW (ABS).** This is an absolute (ABS) power measurement. It shows the amount of optical power being received by the photodetector in microwatts, or millionths of a watt.

## UNIT 2

## Meter Functions

### Operation, cont.

#### Wavelengths

Measurements can be taken for four different wavelengths in the MicroMeter. These wavelengths are 850, 1300, 1310, and 1550nm. All wavelengths are traceable to the National Institute of Standards and Technology (NIST). The user may toggle through these wavelengths by pressing **F3**.

#### “Zeroing” or Setting an Optical Reference

This function allows the user to set references for each wavelength for fiber attenuation testing.

After connecting a light source to the MicroMeter:

- 1 - Toggle the wavelength until it matches the wavelength of the source.
- 2 - Press **0** to zero the meter. The user will be prompted to verify the set reference.
- 3 - Press either **F1** to set the reference, or **F3** to cancel.

**NOTE:** When using laser sources, allow the laser to warm up according to the manufacturer specifications to ensure accurate references.

**NOTE:** In order to set an accurate reference for multimode fibers at 850 or 1300nm, the user must wrap the reference patch cord around a mandrel. The mandrel should be approximately ½” in diameter, and the patch cord should be wrapped 5 to 7 times around the mandrel. The mandrel is necessary for stripping off the optical energy that does not normally travel down the fiber link. If this energy is not removed from the reference value, your fiber readings will be too low, and may cause the link to appear as if it was failing.

#### Monitor Mode

Monitor Mode sends absolute power measurements in a comma delimited format to the serial port in real time. A terminal program is required to view data in real time.

To enter Monitor Mode, press **5** MNO. Press **DONE** to exit Monitor Mode.



#### Powering ON the Integrated LED Source (optional)

If your MicroMeter has an integrated LED light source, it can be turned on and off by pressing the **4** JKL key on the keypad. When the LED is on, an icon will appear in the top right corner of the display as shown at right.




# UNIT 2

## Meter Functions

### Operation, cont.

#### Main Menu

Advanced meter functions can be configured from the Main Menu. Options 1 through 3 are listed in a step-by-step order for certifying fiber links and will be explained in greater detail later in this manual. Options 4 and 5 is explained below. Press **MENU** to enter the MAIN MENU.



```
MAIN MENU
<1>SELECT LINK
<2>DEFINE LINK
<3>TAKE READINGS
<4>STORED DATA
<5>METER SETUP
```

<1>SELECT LINK - This option allows the user to select the fiber link to be used for the test, as well as editing its descriptive name and test date.

<2>DEFINE LINK - This option is used to define the parameters of the fiber link which are used to calculate the link's PASS/FAIL threshold.

<3>TAKE READINGS - This option takes the user to Immediate Mode where they can view power readings, store data points, and switch wavelengths.

<4>STORED DATA - This option allows the user to view and download the data points previously stored in the meter.

<5>METER SETUP - This option allows the user to edit the owner information, and adjust the LCD contrast.

Pressing **DONE** from the MAIN MENU will return the user to Immediate Mode.

#### Stored Data Menu

The STORED DATA menu allows the user to manipulate data that is stored in the MicroMeter.

**NOTE:** if there is no data stored in the MicroMeter, a 'NO STORED DATA' message will appear when any menu option is chosen, and the user will be returned to the STORED DATA menu.

<1>VIEW/EDIT/LOAD - this option allows the user to view, edit, or load any data point that was previously stored in the MicroMeter. The VIEW/EDIT/LOAD screen initially loads with the first data point stored in memory. To go to a different data point, use: **F1** to scroll through the fiber names; **F2** to scroll through the fiber runs for the currently selected fiber name; or **F3** to scroll through the wavelengths for the currently selected data point.

Pressing **0** will LOAD the selected data point, and return the user to Immediate Mode showing the selected data point. From there, the user can continue saving data from that point.

Pressing **5** will EDIT (or reshoot) the selected data point. The user will be returned to Immediate Mode to re-save the data point. After the data point is re-saved, the user is returned to the last data point that was previously stored.

# UNIT 2

## Meter Functions

### Operation, cont.

#### *Stored Data Menu, cont.*

<2>PRINT RANGE - this option allows the user to print data points to a serial device, such as a serial printer or terminal program. The printout is formatted in an easy-to-read format.

<3>DELETE RANGE - this option allows the user to delete a range of data points, or delete all of the data points from the meter. This should only be done after the data points have been downloaded into the PC with Exttech Reporter software.

<4>DOWNLOAD DATA - this option allows the user to download data either to Exttech Reporter software, or to a terminal program. Data downloaded to a terminal program is in a Comma-Delimited format for easy placement into a program that can format Comma-Delimited files. The PC must be connected to the meter via the MicroMeter download cable.

If the user is downloading to Exttech Reporter, then no further action is necessary from this screen. Exttech Reporter will handle the data transfer.

If the user is downloading to a terminal program, then the user must start the terminal program, and press to begin the download.

#### *Meter Setup*

From the MAIN MENU, press **5** to enter the METER SETUP menu. From this menu the user can change company information, such as name and phone number, and can also adjust the contrast of the LCD screen.

COMP NAME **F1** – changes the company name. Press **DONE** after editing the company name.

COMP TELE **F2** – change the company telephone number. Press **DONE** after editing the company telephone number.

ADJ LCD **F3** – adjust the contrast of the LCD display. Press **F1** or **F3** to set the contrast down or up, and then press **DONE** to continue.

#### *Manual Reference Method (recommended for advanced users only)*

The MicroMeter can be used to certify fiber links (shown in detail in the next unit) or to measure link loss by setting a manual reference. The manual reference method is used to measure the actual loss in a fiber link, and it is recommended that only those users who are very familiar with calculating link budgets should use this method.

1 - From Immediate Mode, press **MENU** to enter the MAIN MENU.

### Operation, cont.

#### *Manual Reference Method, cont.*

2 - At the MAIN MENU, press **1** ABC to SELECT LINK. Highlight a link, and press **F3** to change the name and date. Press **DONE** to continue. **NOTE: it is recommended to set the date of test so that it appears on reports.**

3 - Press **F2** to LOAD the selected link, and press **DONE** to continue.

4 - From the MAIN MENU, press **2** DEF to DEFINE LINK, and press **2** DEF to SET A MANUAL REFERENCE. **NOTE: setting a reference with this method will overwrite any previous references.**

5 - Press **F1** to scroll through the wavelengths, and press **F2** to set the manual reference. The asterisk shows the currently selected wavelength.

6 - Type in the manual reference using the keypad, and press **DONE** to continue. Press **DONE** to return to the MAIN MENU.

7) Press **3** GHI to return to Immediate Mode and TAKE READINGS. Data storage is covered in more detail in the next unit.

#### *Power Off*

Press **OFF** to shut down the MicroMeter. The user will be prompted to verify shutdown.

# UNIT 3

## Fiber Certification

### Overview

The whole purpose of fiber certification with the MicroMeter is to save data points using a standards-based reference point and produce professional-looking reports for the customer.

The MicroMeter is capable of storing up to 1000 data points with user-configurable fiber labels, and can certify up to four separate fiber links against the EIA/TIA 568-B standard.

Data points are downloaded into our free Exttech Reporter Windows-compatible software for organizing data points and printing professional-looking certification reports.

### Operation


#### Power On

Press the **ON** button. After a few seconds, the meter will display Immediate Mode (see Unit 2 for a description of the screen).

#### Fiber Certification

The following steps outline the procedure for setting up the MicroMeter for fiber certification. This process begins with running the Link Wizard.

*Definition of a link.* In the MicroMeter, a link is defined as any number of fibers, or fiber runs, that all have the same set of fiber characteristics from one end to the other; typically begin together and end together; and follow the same pathway. These characteristics include fiber length, fiber type, connector loss, and splice loss, as well as the cabling standard being used for fiber certification. **NOTE: Any time one of these fiber characteristics changes, a new link must be configured.** The link wizard uses these characteristics to calculate a reference value which all fibers included in the link are measured against.



1 - Press **MENU** to enter the MAIN MENU.

2 - Press **1** to SELECT LINK.

3 - At the STORED LINKS menu, the currently loaded link is denoted by an asterisk. Scroll through the list of links by pressing **F1** to highlight the link to use. Press **F3** to edit the name and the testing date of the selected link.

3a - Give the link a descriptive name. Press **F1** to edit the name. Press **DONE** to continue.

3b - Enter the date of the test. Press **F2** to enter the date. Press **DONE** to continue.

3c - When the name and date have been entered, press **DONE** to return to the STORED LINKS menu.

4 - Press **F2** to load the selected link. The user will be returned to the MAIN MENU.

# UNIT 3

## Fiber Certification

### Operation, cont.

#### *Fiber Certification, cont.*

5 - Press **2** DEF to DEFINE LINK.

6 - Press **1** ABC to CERTIFY LINK.

6a - Scroll through the list of fiber types and highlight the link's fiber type. Press **F2** to select.

6b - Enter the length of the fiber in meters. Press **DONE** to continue.

6c - Enter the number of inline connections (connector pairs) in the link. Press **DONE** to continue.

6d - Enter the number of inline splices in the link. Press **DONE** to continue.

6e - Connect the light source for the wavelength shown on the display (remember: if the user is testing multi-mode fibers, the test jumper must be wrapped 5-7 times around a mandrel). Press **F1** or **DONE** to continue.

The settings the user just entered will appear on the display.

*SRC PWR (shown in dBm)* - actual power the light source is emitting.

*100 m (shown in dB)* - attenuation value associated with the length and type of fiber the user entered.

*0 CONN (shown in dB)* - attenuation value of the connectors and splices the user entered.

*REF PWR (dBm)* - source power plus fiber attenuation plus connector and splice attenuation. This is the PASS / FAIL threshold.

*850nm* - wavelength that the reference is being set for.

*M6* - fiber type that the reference is being set for (M6 = 62.5  $\mu$ m multi-mode, M5 = 50 $\mu$ m multi-mode, SI = single mode indoor, SO = single mode outdoor).

7 - If any of the fiber characteristics were entered incorrectly, press **F2**. The user will be asked to repeat steps 6a through 6e.

8 - Press **F3** to save the reference. **NOTE: The reference will not be saved if the users does not press **F3**.** A screen will appear for about 2 seconds verifying the reference being set.

9 - If the user is testing an additional wavelength, press **F1**. The user will be prompted to connect a light source for the other wavelength as in step 6e.

10 - Press **DONE** to continue. The user will be returned to the MAIN MENU.

The screenshot shows a monochrome LCD display with two sections. The top section displays test parameters: SRC PWR = -20.24, 100 m = -00.35, 0 CONN = +00.00, REF PWR = -20.62, and 850nm M6. The bottom section is a menu with three options: WAVE | EDIT | SAVE, LEN | LINK | REF.

## UNIT 3

## Fiber Certification

### Operation, cont.

#### *Fiber Certification, cont.*

11 - At this point, the user is ready to take readings. Remove the reference patch cord from the MicroMeter, but make sure that the patch cord stays connected to the light source for the duration of the test. This is very important, as removal of the patch cord during the test will invalidate the reference set during the Link Wizard.

12 - Take the MicroMeter and connect it to one end of the link under test, and take the light source and reference patch cord to the other end and do the same.

13 - Press **3** to TAKE READINGS. The user will be returned to Immediate Mode. Immediate Mode is explained in better detail in Unit 2.

14 - Press **F1** to set the display units to dB REL (see display at right). This will tell the user if the fiber under test passes or fails, and by how much. **NOTE: a test that passes will have a plus sign, and a failed test will have a minus sign. Also, take note if the pass/fail number is close to 0.00 dB. This means that the fiber is marginal and should be inspected, even if it passes.**



```
+ 2.45 dB REL
82%
68%
<PASS 568>
FIBER LINK #1
FBR:00 850nm
-----
UNITS | STORE | WAVE
```


15 - Press **F2** to STORE a data point. The user may be prompted to enter a label. It is recommended to change the label to better describe the fiber runs being stored. Press **DONE** to continue.

16 - The user may be prompted to enter the fiber type. This fiber type must match the fiber type chosen in the Link Wizard. Scroll through the fiber types with the **F1** key, and press **F2** to select. The user will only have to enter the fiber type if they have not saved a data point for the current label.

17 - Press **F3** to save the current data point and continue on to the next fiber.

18 - Repeat steps 15 and 17 for each data point to save. If the fiber label needs to be changed, press **F2** at the Data Point Save Screen and follow the steps on the screen.

19 - If the user is testing at additional wavelengths, press **F3** while in Immediate mode to toggle to the next wavelength. The auto-increment number will begin at '00' again, and have the same label.



```
FIBER LINK #1
NAME = FBR:00
TYPE=62.5um MM
-22.05dBm 850nm
-----
PRINT | EDIT | 
DATA | NAME | SAVE
```

### Operation, cont.


#### *Stored Data*

Before downloading certification data points to a PC, the user must first have installed free Extech Reporter software on it. This software can be installed from the enclosed CD.

- 1 - Power on the MicroMeter and connect it to the PC COM port via the supplied DB9 download cable.
- 2 - Start the Extech Reporter software on the PC.

3 - Click the Download option on the menu bar, or the Download button on the button bar (as shown on the right). The data points that are stored in the meter will appear in the Extech Reporter window.

Once the data is downloaded into Extech Reporter, we recommend that the user saves them as an Extech Reporter file for permanent storage.



If a hard copy of the data points is needed, they may be printed. There are two report options: summary and detail. The summary printout lists all of the data points together, shows whether the link passed or failed, and shows the power level of the fiber. A sample summary report is located on the next page.

The detail printout prints each individual fiber run on a single page, and shows detailed information about the run, including whether the fiber passed or failed, and the remaining overhead of the fiber run.

## CIRCUIT SUMMARY PRINTOUT

At the right is an example of the Circuit Summary Report. Below are descriptions of the columns:

*Circuit ID* - this is the name of the fiber that was tested.

*P/F* - shows whether the test passed or failed.

*850nm* and *1300nm* - shows the amount by which the test passed or failed by at the wavelength tested.

Reports such as the one at right are useful for overall evaluation of a fiber links PASS/FAIL status.

Closer inspection of the PASS/FAIL values could reveal problems with individual fibers, or with termination, installation, or test methods.

For example, when looking at the values in the report at the right, notice that they vary from 1.20 dB to 5.61 dB. Because there is quite a large difference in the high and low numbers, this might indicate an inconsistency with fiber termination and

polishing methods. Poorly polished fiber connectors will produce additional loss and cause the PASS/FAIL margin to shrink. In our example, let us say that the customer requires a 2 dB safety margin. Thus, the fibers with less than 2 dB of margin should be re-evaluated.

## Company Name

Link ID: \_\_\_\_\_ FBR: \_\_\_\_\_

Company Name: \_\_\_\_\_

Telephone Number: \_\_\_\_\_

Page: 1

Report Date: 08/26/2003

Circuit ID	Date	P/F	850nm	P/F	1300nm
01	08/22/2003	Pass	1.47dB	Pass	1.20dB
02	08/22/2003	Pass	4.45dB	Pass	3.19dB
03	08/22/2003	Pass	2.67dB	Pass	4.50dB
04	08/22/2003	Pass	5.10dB	Pass	2.51dB
05	08/22/2003	Pass	3.53dB	Pass	5.28dB
06	08/22/2003	Pass	5.61dB	Pass	1.74dB
07	08/22/2003	Pass	4.49dB	Pass	3.17dB
08	08/22/2003	Pass	4.98dB	Pass	4.98dB
09	08/22/2003	Pass	3.17dB	Pass	4.49dB
10	08/22/2003	Pass	1.74dB	Pass	5.61dB
11	08/22/2003	Pass	5.28dB	Pass	3.53dB
12	08/22/2003	Pass	2.51dB	Pass	5.10dB
13	08/22/2003	Pass	4.50dB	Pass	2.67dB
14	08/22/2003	Pass	3.19dB	Pass	4.45dB
15	08/22/2003	Pass	1.20dB	Pass	1.47dB

\*1 - Manually set reference    \*2 - Fiber type mismatch    \*3 - Not covered by TIA standard

Installer/Tester: \_\_\_\_\_

Customer: \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

## Appendix A - Decibel Review

Your MicroMeter meter has a decibel(dB) range that spans 75dB. The whole purpose of your meter is to measure light energy in decibels. But what exactly is a decibel? It is not uncommon for a technician to be using an optical power meter and not understand what a decibel really is. If you struggle a little with this review, you will find the concept not so threatening.

This is what happens when we test a link: we send light of a specified wavelength from a stable light source down the fiber optic cabling. The meter then captures this light and measures it. As light travels down this path, however, its photons encounter impurities, connector gaps, and even the glass atoms themselves. All of these factors cause attenuation in the fiber. If there is too much attenuation, your fiber optic link will fail, because it does not have enough power to trigger the circuitry in the active receiver equipment. No communications can occur in this scenario.

Simply put, a decibel is a measure of the ratio of the power received at the end of a link relative to the power you started with, which is known. This fraction calculates the relative power. This calculation is similar to test scores or percentages.

$$\frac{\text{Amount of optical power left over at the end of the link}}{\text{Amount of optical power at the beginning of the link}} \times 100 = \text{Relative power out as a \%}$$

If test results were kept in percent or fractions, the average person wouldn't have difficulty in grasping the concept of decibels. Unfortunately, in scientific measurement, graphing power measurements has become too cumbersome due to their wide range of possible values; a person would need to paste lots of sheets of graph paper together to plot these power functions by hand. So scientists came up with a little trick to "squeeze" the graph down to a more presentable size. The trick uses logarithms (logs). Logs are fairly simple -- most of us have already encountered logs in pre-algebra class. They didn't seem so important then, but they are important to the understanding of decibels. Logs expressed in Base 10 are just a way to state how many zeros there are in a number.

For example,  $\log(10)=1$ ,  $\log(100)=2$ ,  $\log(1000)=3$ . Notice the pattern. Logs simply express how many places there are after the first number. Let's work with a number that isn't 10, 100, or 1000. For instance the  $\log(2014)=3.304$ . Notice that 2014 has three digits beyond the first, thus the "3" in the 3.304. Also notice how it relates to the "3" in  $\log(1000)=3$ . Remember, logs are a tool we use to "squeeze" our measurements down so they will fit on graph paper.

$$\text{LOG}\left(\frac{\text{Amount of optical power left over at the end of the link}}{\text{Amount of optical power at the beginning of the link}}\right) = \text{Relative power as a power of 10}$$

Power is measured in Watts (W), therefore:

$$10 \text{ LOG}\left(\frac{W_{\text{END OF LINK}}}{W_{\text{BEGINNING OF LINK}}}\right) = \text{Relative power as a power of 10}$$

**Appendix A - Decibel Review, cont.**

Mathematicians and scientists must have noticed that the shrinking effect of the graph was a little excessive. Logs in optical decibels get multiplied by 10. Thus we finally have:

$$\text{LOG}\left(\frac{W_{\text{END OF LINK}}}{W_{\text{BEGINNING OF LINK}}}\right) = \text{Relative power as a power of 10}$$

Remember: Decibels are simply the ratio of the power received by the receiver over the power sent out by the light source at the start of link.

There are other decibels to consider. The decibel we previously described is "dB" is called relative. This is because it is a ratio as was explained. With ratios there is no way to tell what absolute value we had at the start or end of a link. To solve the problem we can always reference our optical power to a fixed value of one milliwatt (1 mW). One milliwatt of power will replace the denominator of our equation.

$$10 \text{ LOG}\left(\frac{W_{\text{END OF LINK}}}{1 \text{ mW}}\right) = \text{Absolute power in dB}$$

So when we are given a value of absolute power in dBm we know that it is the power relative to 1 mW and we can calculate the actual power in mW if necessary. We can also compare values in dBm to each other because they are relative to the same reference (1mW). However, we cannot compare values in dB to each other because we do not know if they are relative to the same reference.

**Appendix B - Dynamic Range Review**

Now that you have a clearer understanding of the decibel, we can begin to study the dynamic range feature of the MicroMeter. The dynamic range of the MicroMeter is +5 to -70 dBm, but what exactly does this mean?

Dynamic range is defined as the difference between the minimum and maximum power levels that a photodetector can reliably sense, and still maintain acceptable accuracy. In the case of the MicroMeter, the dynamic range is 75dB.

Any power level reaching the detector that is greater than +5 dBm is too powerful to accurately measure. Likewise, any power level below -70 dBm will be too weak to be sensed.

Power levels within the dynamic range produce acceptable readings. It is interesting to note that the MicroMeter remains accurate over the upper 96% of the 75 dB dynamic range and then gets progressively worse as the power levels drop off.

The limits of dynamic ranges depend on certain factors. The minimum level depends on the sensitivity of the receiver. The sensitivity of the receiver can be increased by using different materials, such as germanium (Ge) or indium/ gallium/arsenide (InGaAs). The characteristics of these materials allows the detector to be responsive at lower power levels. The maximum level depends on both the size of the receiver area , and also the amplifier used.

### Appendix C - Glossary

**Absorption.** The loss of power in an optical fiber, resulting from conversion of optical power into heat and caused principally by impurities, such as transition metals and hydroxyl ions, and also by exposure to nuclear radiation.

**Acceptance Angle.** The half-angle of the cone within which incident light is totally internally reflected by the fiber core. It is equal to  $\arcsin(\text{NA})$ .

**Attenuation.** A general term indicating a decrease in power from one point to another. In optical fibers, it is measured in decibels per kilometer at a specified wavelength.

**Bandwidth.** The transmission capacity of a system.

**Buffering.** 1. A protective material extruded directly on the fiber coating to protect the fiber from the environment (tight buffering). 2. Extruding a tube around the coated fiber to allow isolation of the fiber from stresses on the cable (loose buffered)

**Buffer Tubes.** Loose-fitting covering over optical fibers used for protection and isolation.

**Bundle.** Many individual fibers contained within a single jacket or buffer tube. Also, a group of buffered fibers distinguished in some fashion from another group in the same cable core.

**Cladding.** The outer concentric layer that surrounds the fiber core and has a lower index of refraction.

**Connector.** A mechanical device used to provide a means for aligning, attaching, and achieving continuity between fibers.

**Consolidation Point.** A location for interconnection between horizontal cables that extend from building pathways and horizontal cables that extend into work area pathways.

**Core.** The central, light-carrying part of an optical fiber; it has an index of refraction higher than that of the surrounding cladding.

**Cross-Connection.** A connection scheme between cabling runs, subsystems, and equipment using patch cords or jumpers that attach to connecting hardware on each end.

**Decibel (dB).** In fiber optics, a standard logarithmic unit for the ratio of the power that was received over the power that was originally sent.

**dBm.** Decibel referenced to a milliwatt.

**dBμ.** Decibel referenced to a microwatt.

**Detector.** An optoelectronic transducer used in fiber optics for converting optical power to electric current. In fiber optics, usually a photodiode.

**Diffraction.** The bending of radio, sound, or light waves around an object, barrier, or aperture edge.

### Appendix C - Glossary, cont.

*Dispersion.* A general term for those phenomena that cause a broadening or spreading of light as it propagates through and optical fiber. the three types are modal, material, and waveguide.

*Entrance Facility.* An entrance to a building for both public and private network service cables including the entrance point at the building wall and continuing to the entrance room or space.

*Equilibrium Mode Distribution (EMD).* The steady modal state of a multimode fiber in which the relative power distribution among modes is independent of fiber length.

*Equipment Room.* A centralized space for telecommunications equipment that serves the occupants of the building. Equipment housed herein is considered distinct from a telecommunications closet because of its nature or complexity of the equipment.

*Frequency.* Of a periodic wave, the number of identical cycles per second. Usually expressed in Hertz.

*Fresnel Reflection.* The reflection that occurs at the planar junction of two materials having different refractive indices; Fresnel reflection is not a function of the angle of incidence.

*Graded-index Fiber.* An optical fiber whose core has a nonuniform index of refraction. The core is composed of concentric rings of glass whose refractive indices decrease from the center axis. The purpose is to reduce modal dispersion and thereby increase fiber bandwidth.

*Horizontal Cross-Connect (HC).* A cross-connect of horizontal cabling to other cabling, e.g., horizontal, backbone, equipment.

*Index of Refraction.* The ration of the velocity of light in free space to the velocity of light in a given material.

*Insertion Loss.* The loss of power that results from inserting a component, such as a connector or splice, into a previously continuous path.

*Interconnection.* A connection scheme that provides for the direct connection of a cable to another cable or to an equipment cable without a patch cord or jumper.

*Intermediate Cross-Connect (IC).* A cross-connect between the main cross-connect and the horizontal cross-connect in backbone cabling.

*Laser.* Light Amplification by Stimulated Emission of Radiation. A light source producing, through stimulated emission, coherent, near monochromatic light. Lasers in fiber optics are usually solid-state semiconductor types.

*Light-Emitting Diode (LED).* A semiconductor diode that spontaneously emits light from the PN junction when forward current is applied.

*Main Cross-Connect (MC).* The cross-connect in the main equipment room for connecting entrance cables, backbone cables, and equipment cables.

### Appendix C - Glossary, cont.

*Material Dispersion.* Dispersion resulting from the different velocities of each wavelength in an optical fiber.

*Modal Dispersion.* Dispersion resulting from the different transit lengths of different propagating modes in a multimode optical fiber.

*Mode.* A possible path followed by light rays.

*Multi-mode Fiber.* A type of optical fiber that supports more than one propagating mode.

*Numeric Aperture (NA).* The number that expresses the light-gathering ability of a fiber.

*Optical Time Domain Reflectometry (OTDR).* A method of evaluating optical fibers based on detecting backscattered (reflected) light. Used to measure fiber attenuation, evaluate splice and connector joints, and locate faults. Also, the equipment used to perform such measurements (Optical Time Domain Reflectometer).

*Photodetector.* An optoelectronic transducer, such as a PIN photodiode or avalanche photodiode.

*Photodiode.* A semiconductor diode that produces current in response to incident optical power and used as a detector in fiber optics.

*Photon.* A quantum of electromagnetic energy; a particle of light.

*Receiver.* An electronic device which converts optical signals to electrical signals.

*Responsivity.* The ratio of a photodetector's electrical output to its optical input in an optical fiber.

*Single Mode Fiber.* An optical fiber that supports only one mode of light propagation above the cutoff wavelength.

*Source.* The light emitter, either an LED or laser diode, in a fiber optic link.

*Spectral Width.* A measure of the extent of a spectrum. For a source, the width of wavelengths contained in the output at one half of the wavelength of peak power. Typical spectral widths are 20 to 60 nm for an LED and 2 to 5 nm for a laser diode.

*Splice.* An interconnection method for joining the ends of two optical fibers in a permanent or semi-permanent fashion.

*Step-Index Fiber.* An optical fiber, either multi-mode or single mode, in which the core refractive index is uniform throughout so that a sharp step in refractive index occurs at the core-to-cladding interface. It usually refers to a multi-mode fiber.

*Telecommunications Closet (TC).* An enclosed space for housing telecommunications equipment, cable terminations, and cross-connects. The closet is the recognized cross-connect between the backbone cable and horizontal cabling.

### Appendix C - Glossary, cont.

**Tight Buffer.** A cable construction where each fiber is tightly buffered by a protective thermoplastic coating to a diameter of 900  $\mu$ M.

**Transmitter.** An electronic package which converts an electrical signal to an optical signal.

**Wavelength.** The distance between the same two points on adjacent waves; the time required for a wave to complete a single cycle.

**Work Area.** A building space where the occupants interact with telecommunications terminal equipment; i.e. PCs, telephones, and other office equipment.

### Appendix D - MicroMeter Specifications

Detector Type	Ge (1mm)
Calibrated Wavelengths	850, 1300/1310, 1550
Measurement Range	+5 to -70 dBm
Accuracy	$\pm 0.15$ dB
Resolution	0.01
Battery Life	up to 100 hours (9V)
Connector Type	Universal 2.5mm
Operating Temperature	-10 to 55 C
Storage Temperature	-30 to 70 C
Size	2.75" W x 5.0" H x 1.3" D
Weight	6 oz.
Data Storage Points	up to 1000
Download Data Points	Extech Reporter v1.x.x
Absolute/Relative Measurements	Yes
Battery Capacity Display	Yes
Backlight	Yes
NIST Traceable	Yes

### Appendix E - Warranty and Repair/Calibration Information

#### WARRANTY

**EXTECH INSTRUMENTS CORPORATION** warrants this instrument to be free of defects in parts and workmanship for **one year** from date of shipment (a six month limited warranty applies to sensors and cables). If it should become necessary to return the instrument for service during or beyond the warranty period, contact the Customer Service Department at (781) 890-7440 ext. 210 for authorization or visit our website [www.extech.com](http://www.extech.com) for contact information. A Return Authorization (RA) number must be issued before any product is returned to Extech. The sender is responsible for shipping charges, freight, insurance and proper packaging to prevent damage in transit. This warranty does not apply to defects resulting from action of the user such as misuse, improper wiring, operation outside of specification, improper maintenance or repair, or unauthorized modification. Extech specifically disclaims any implied warranties or merchantability or fitness for a specific purpose and will not be liable for any direct, indirect, incidental or consequential damages. Extech's total liability is limited to repair or replacement of the product. The warranty set forth above is inclusive and no other warranty, whether written or oral, is expressed or implied.

#### REPAIR AND CALIBRATION SERVICES

**Extech offers repair and calibration services** for the products we sell. Extech also provides NIST certification for most products. Call the Customer Service Department for information on calibration services available for this product. Extech recommends that annual calibrations be performed to verify meter performance and accuracy.



#### **Support line (781) 890-7440**

Technical support: Extension 200; E-mail: [support@extech.com](mailto:support@extech.com)

Repair & Returns: Extension 210; E-mail: [repair@extech.com](mailto:repair@extech.com)

### Appendix F - Cleaning and Care Instructions

- 1 - Take great care to NOT drop any piece of scientific equipment, e.g. the MicroMeter. Damage may occur to the case or electronic components on the circuit board may become dislodged, and inaccuracy may occur.
- 2 - Keep the meter in its neoprene case when not in use. This will help protect the meter from the elements and accidental droppage.
- 3 - Store the meter in a cool dry area when not in use in order to keep the meter in top working condition.
- 4 - We recommend not removing the universal connector as it is not necessary for cleaning. Its parts are very fragile, small, and easy to lose.
- 5 - Always remember to replace the rubber cap on the connector. This will keep dust and dirt out of it when you are not using the meter.
- 6 - Use only 99% or better Isopropyl alcohol when cleaning the detector. Any less than 99% contains too much water and will begin to corrode the components. 99% Isopropyl alcohol is very flammable, so additional care must be taken when cleaning the detector. 99% Isopropyl alcohol can be purchased at your local drug store.
- 7 - Whenever possible, use specially designed 2.5mm cleaning sticks to clean the detector. These do not require alcohol and do not damage the insides of the connector. Do not used sticks or swabs of any other type because they may damage the zirconium ferrule or the coating of the detector inside the connector, or may leave behind dust or fibers that will add loss to the fiber reading.
- 8 - The detector port should be cleaned at the beginning and end of the testing day to keep connector loss during testing at a minimum.
- 9 - When cleaning the meter itself, do not use any household cleaner that contains ammonia as this will damage any plastic it comes in contact with.
- 10 - The case is splash-proof, so it is not necessary to clean the inside of the meter.
- 11 - Only use lint-free cloths. Anything else may scratch the plastic of the display.


## Appendix G - Reference Cable Setup

Your test jumpers must be cleaned and inspected prior to using them for fiber link testing. You should have one jumper for the power meter side of the test, and one jumper for each of the connector ports on your light source. Make sure that these patch cords match the fiber under test (i.e. same fiber type, same core/cladding size, same connector type).

Use the following steps to set up your reference jumpers for link testing:

- 1 - Connect the first jumper to the power meter and light source. Verify that it is working properly and not introducing significant loss to the test. Disconnect this patch cord from the light source and meter and set it aside.
- 2 - Connect the other patch cord(s) to the light source. If you have a dual wavelength light source with two connector ports, then it is recommended to connect one jumper to each port.
- 3 - MULTIMODE ONLY. If you are testing multimode fibers, you will need to wrap each of the jumpers connected to the light source around a  $\frac{1}{2}$ " mandrel at least 5 times. This is done to achieve Equilibrium Mode Distribution (EMD), which eliminates unwanted optical energy that can cause inaccurate test results.
- 4 - Run the Link Wizard. You will be prompted to connect the patch cords during this process, once for each wavelength. See Unit 3 for detailed instructions.

**NOTE:** Do NOT remove the patch cords from the light source until you have completed testing all of the fibers in the link. Disconnecting the test jumper from the light source and re-connecting it will cause the Link Wizard reference to be incorrect, thereby producing incorrect readings, and may cause a link to fail.



**Multimode  
Reference**



**Single-mode  
Reference**

## Link Budget Calculation Worksheet

Operating Wavelength  Fiber Type

### Calculate System Attenuation

Fiber Loss at Operating Wavelength (Distance x Fiber Loss)

Total Cable Distance  km  
 Individual Fiber Loss (at operating wavelength)  dB/km  
 Total Fiber Loss  dB  
 Connector Loss (Connector Loss x Connector Pairs)  
 Individual Connector Loss  dB  
 Number of Connector Pairs   
 Total Connector Loss  dB  
 Splice Loss (Splice Loss x Splices)  
 Individual Splice Loss  dB  
 Number of Splices   
 Total Splice Loss  dB  
 Other Components  dB  
 Total System Attenuation  dB

### Calculate Link Loss Budget

Determine System Gain (Avg. Transmitter Power - Receiver Sensitivity)

Average. Transmitter Power  dBm  
 Receiver Sensitivity  dBm @  $10^{-9}$  BER  
 System Gain  dB

Power Penalties (Operating Margin + Receiver Power Penalties + Repair Margin # Splices at 0.3dB each)

Operating Margin  dB  
 Receiver Power Penalties  dB  
 Repair Margin  dB  
 Total Power Penalty  dB

Determine Link Loss Budget (System Gain - Power Penalty)

System Gain  dB  
 Total Power Penalty  dB  
 Total Link Loss Budget  dB

### Verify Performance

Verify Adequate Power (Total Link Loss Budget - Total System Attenuation)

Total Link Loss Budget  dB  
 Total System Attenuation  dB  
 System Performance Margin\*  dB

\* System Performance Margin must be greater than 0 dB in order for the system to operate using the specified electronics.